




600x600mm finger module, 2x112 LEDs



Features

- Finger board for 600x600mm fixture;
- Dimension: 543x250mm (single board);
- Up to 8691 lm;
- Up to 196 lm/W;
- CRI 80, 90;
- Max Electrical Insulation 250V;
- Lifetime >60000h @ 350mA.

Applications











R4218



600x600mm finger module, 2x112 LEDs

Code	ССТ	CRI	Current [mA]	Voltage [V]	Power [W]	Total Lumen* [lm]	lm/W	Energy Efficiency
R4218113080	3000K	80	350	48,8	17,08	3136	184	С
			700	49,6	34,72	5645	162	D
			1050	50,4	52,92	8467	160	D
R4218114080	4000K		350	48,8	17,08	3248	190	С
			700	49,6	34,72	5768	166	D
			1050	50,4	52,92	8579	162	D
R4218115080	5000K		350	48,8	17,08	3360	196	С
			700	49,6	34,72	5880	169	D
			1050	50,4	52,92	8691	164	D

* Typical Value refers to datasheet Edison 2835 0,5W PLCC Tj=25°C Flux Tollerance +/- 10% Vf Tolerance +/-0,06V

Led and board features					
Led number	224 (2 x 112)				
Led	EDISON OPTO 2835 or similar				
Circuit	2 x S8P14 connected in series				
Material	FR4				
Solder	WHITE				
Connections					
Cable	AWG 24-18 (0,2-0,75mm2)				
Connector	2060 Poke In				
Power					
Abs. Max Input current CC	1050mA				
Mechanical Data					
HxL	543,4x250mm				
Thickness	6,1mm				
Conditions					
Max. temp. (Tp)	85°C				
Max. temp. (Tc)	75℃				
Operating temp. Range	-25°C +50°C				









600x600mm finger module, 2x112 LEDs



Mechanical drawing







1 *YLED 對語 社LD15 *本FE5。 *本FE9。 *本FE9: * LED * LED * LED * LED * LED +++LED ¥中LED +++LED ¥女LED ¥中LED *456 *456 *456 HED LD78 * CON * CLONE * CLONE * CLONE * CLONE +++LED 44LED +++LED ATLED +++LED *YLD87 *YLED *中LD32 ≩¢LED 社LED *2LED LED St 社的7 之 中 LED *YLE107 * YLED *本repa *本repa *本repa *本repa LDI12

Electrical circuit

1 1

600x600mm finger module, 2x112 LEDs









Assembly and Safety Information

Installation must be carried out under observation of the relevant regulations and standards. The LED modules are designed for operation within a casing or luminaire. Installation must be carried out in a voltage-free state (i.e. disconnection from the mains). The following advice must be observed; non-observance can result in the destruction of the LED assembly modules, fire and/or other hazards.

• Consider safety regulations acc. EN 60598 in the luminaire design, especially when the operating LED driver is not galvanic isolated.

– In mode of operation regard to sufficient isolation.

- Live parts must not be touched in operation mode. Danger in life!!!

• ESD (electrostatic discharge) protection measures must be observed when handling and installing the LED modules. See VS's application notes on ESD protection.

• Adequate anti-static electricity measures, including the use of conductive shoes, ionizers, work bench grounding, wrist straps, flooring and stools should be used.

• LED assembly modules must not be subjected to any undue mechanical stress, e.g.:

- do not treat as bulk cargo
- avoid shear and compressive forces during handling and installation
- do not damage circuit paths
- avoid any pressure on the light emitting surface

• Safe operation only possible by the use of external constant current sources (Imax. see table "Electrical Characteristics").

• Operation only with power supply units that feature the following protection:

- Short-circuit protection
- Overload protection

- Overheating protection

• The module can be fixed with M3 screws. Fixation only with flat or cylinder head screws (M3) (no countersank screws) Max. torque: 1.2 Nm (M3)

• Please ensure the correct polarity of the leads prior to commissioning. Reversed polarity can destroy the modules.

• For interconnection the LED modules is equipped with push-in terminals (WAGO 2060).

• Safety regulations acc. to EN 60598 (or further standards) has to be observed if the maximum output voltage exceed the permitted touchable value.

• The following points must be observed when connecting LED modules in parallel:

- All LED strings that are wired in parallel must contain the same number of LEDs (symmetrical loading).

- Owing to differing forward biases, there can be a difference of up to 10% in brightness between modules connected in parallel.

• To ensure problem-free operation, the specified maximum temperature at the tp point (see "Operating Life") must be observed (and measured in accordance with EN 60598-1). To satisfy this point, it may be necessary to put measures in place to ensure any heat is dissipated from the PCB to the environment.

• In the event of outdoor applications or applications in damp locations, care must be taken to protect LED assembly modules against humidity, splashes and jets of water. Any corrosion damage resulting from humidity or contact with condensation will not be recognized as a defect or manufacturing fault. LED assembly modules are not specially protected against foreign bodies or dust. Depending on the type of application, further protection must be ensured to prevent dust and foreign bodies from entering.

• Due to the manufacturing process, the PCBs of the LED assembly modules can have sharp edges and corners. Care must therefore be taken during handling and installation to avoid injury.

• For optimal load of used constant current driver the modules can only be connected in series. The quantity of LED modules is limited by the sum of forward voltage and the capacity of used constant current driver. Safety regulations acc. to EN 60598 has to be observed if the sum of forward voltage exceed the permitted touchable value.

• Operating LED modules in the presence of certain chemical substances or in chemically enriched (aggressive) environments can impair module functionality or even cause total module failure.

• The photobiological safety of the LED modules must be classified into risk groups in accordance with IEC / TR 62778: risk group 1 (except HB, 6500 K, > 500 mA: risk group 2)

Applied Standards

IEC / EN 62031 LED modules for general lighting – Safety specifications

IEC /TR 62778

Application of IEC 62471 for the assessment of blue light hazard to light sources and luminaires